

# **Fireworks Code Regulations for Tents & Temporary Stands**

- **NO Smoking Signs**

1. NO Smoking in or within 50 feet of **Consumer Fireworks Retail Sales (CFRS)** NFFPA 1 – 65.10.3.11.1
2. NO smoking signs posted at each entrance or within 10 feet of every aisle. "FIREWORKS – NO SMOKING" signs posted in 2 inch lettering with contrast background NFFPA 1 – 65.10.3.11.2

**\*\*NOTE:** In accordance with NFFPA 1 Section 65.10.4.8.3 and 65.10.4.8.4, exit signs and emergency lights are not required for tents to be illuminated that are not open for business after dusk in accordance with NFFPA 1124 section 7.4.8.3 and 7.4.8.4.

- **Separation Distances for Temporary Consumer Fireworks Retail Sales (CFRS)**

1. 50 feet from motor fuel dispensing station NFFPA 1 – 65.10.3.12.2
2. 50 feet from retail propane dispensing station NFFPA1 - 65.10.3.12.1
3. 50 feet from aboveground storage tank (AGST) NFFPA1 - 65.10.3.12.1
4. 300 feet from bulk fuel dispensing or bulk storage NFFPA 1 – 65.10.3.12.6
5. 20 feet from buildings NFFPA 1 – 65.10.4.7.2
6. 20 feet from combustibles NFFPA 1 – 65.10.4.7.2
7. 10 feet from parked vehicles NFFPA 1 – 65.10.4.7.2
8. 20 feet from storage of consumer fireworks NFFPA 1 – 65.10.4.7.2
9. 20 feet from generator fuel storage NFFPA 1 – 65.10.4.9.2.3
10. 20 feet from generator placement NFFPA 1 – 65.10.4.9.2.2
11. 20 feet from cooking equipment NFFPA 1 – 65.10.4.9.3.1
12. 50 feet from any open flame cooking equipment NFFPA 1 – 65.10.4.9.3.2

- **Proper Use of Extension Cords**

NFFPA 1 – 11.1.7

1. Extension cords maintained in good working condition.
2. Extension cords shall be grounded when serving ground appliances.
3. Extension cords cannot be used as permanent wiring.
4. Extension cords shall be rated for its use.
5. Extension cords shall be plugged directly into an approved receptacle, powertap or multi-plug adapter.

- **Fire Extinguishers**

1. Travel distance to extinguisher shall be 35 feet or less NFFPA 1 – 65.10.4.5.2
2. Every CFRS facility and store shall have a minimum of 2 portable Fire extinguishers (one 2A rating and one 2 ½ gallon pressurized water type extinguisher) NFFPA 1 -65.10.3.6.3

- **Notification to Local Fire Department of storage.**

1. (Shall include address of sales, address, where fireworks are stored, and how they are stored, copy of shipping bill or manifest and whether fireworks are consumer, theatrical pyro or display.) KRS 227.752(3)
2. 24 hours to comply with any non-imminent danger violations. KRS 227.752(4)

## **Fireworks Code Regulations for Tents & Temporary Stands**

- **Discharging Fireworks Signage** - One sign shall be posted on exterior of each side of the CFRS stating "No fireworks discharge within 200 feet." 4 Inch lettering on contrast Background. NFPA 1 – 65.10.4.6.3  
KRS 227.715(11)
- **Ignition of fireworks** - person lawfully possessing consumer fireworks may use them if: 18 years old, fireworks not ignited within 200 feet of any structure, vehicle or other person. KRS 227.715(11)
- **Temporary Stands (Not accessible to the public)**
  1. Maximum height of displays – 8 feet. NFPA 1 – 65.10.6.4.3
  2. Items shall not be required to have covered fuses NFPA 1 – 65.10.6.4.5
  3. Fireworks shall be displayed in a manner that prevents handling by persons other than staff NFPA 1 – 65.10.6.4.6
- **Temporary Stands (accessible to the public)**
  1. Stands less than 200 square feet only 1 fire extinguisher required NFPA 1 – 65.10.6.2.1
  2. Approved safety and evacuation plan not required NFPA 1 – 65.10.6.2.2
  3. Travel distance to exits shall not exceed 35 feet NFPA 1 - 65.10.6.2.3.2
- **Under The Influence** - NO sale of fireworks to anyone obviously under the influence of alcohol or drugs NFPA 1 – 65.10.3.23
- **Training** - All personnel handling consumer fireworks shall receive training to the performance of their duties. NFPA 1 – 65.10.3.22
- **Building Permit for Tent** - Building permit must be obtained to the installation or erection of a tent over 399 square feet 2013 KBC – 105.1
- **Fireworks registration displayed conspicuously for each location selling fireworks** KRS 227.715(6)
- **No person under 18 years old shall sell consumer fireworks at CFRS facility without supervision of parent or guardian** KRS 227.715(9)
- **No person shall give, offer for sell any consumer fireworks to anyone under 18 years old** KRS 227.715(8)